



**Bruhat Bengaluru
Mahanagara Palike**

**Office of the Executive Engineer [Town Planning]
III Floor, Annexe Building No.2, N R Road,
BANGALORE-560 002**

Ref No: EETP/BBMP/1176/MA/2018-19

12TH June 2018

BUILDING SAFETY CERTIFICATE

This is to herewith certify that the Building Constructed by the Certified Structural Engineer of the Bruhat Bengaluru Mahanagara Palike, was inspected by the undersigned on 6th June 2018 & the same was assessed based on Visual Inspection, Building Safety Test and Approved Building Plans.

1. ADDRESS OF THE BUILDING: **AMRITA VIDYALAYAM, Mata Amritanandamayi Ashram, #136, Mata Amritanandamayi Road, Jnanabharathi II St, Ullala Upanagara Post, BANGALORE**
2. The existing school Building comprises of, Ground Floor [GF] + 3 Upper Floors with RCC Roof Construction.
3. Building having started constructed in the year 2004, in Phases and completed in the year 2014 with RCC Columns and Beams-RCC Framed Structure with 8.5" thick walls in between all the blocks, North, South and West sides are in good conditions with good ventilation and Spacious Class Rooms [26'0" x 21'6" x 12'6"] with 6' Wide Corridors, Spacious Laboratories, Audio Video Rooms, Seminar Halls [GF & 3RD Floor], Staircases at 4 Locations and with Sufficient Toilets and Rest Rooms.
4. The foundation for the structure is rested on Hard Soil, with Safe Bearing Capacity [S.B.C.] of Soil around 23 T /Sq.mt & the building is designed for GF + 3 Upper floors designed compliance to Institutional Purpose. The Slabs and Beams are designed as one way/two way slabs with Beams & Columns as per design drawings & also all the Rooms are able to accommodate around 35 people strength.
5. Based on visual inspection, it was found that all Beams / Column sizes are as per drawings and no cracks were observed; hence the building is safe enough for the Serviceability Criterion.

Handwritten signature and date: 12/6/18





**Bruhat Bengaluru
Mahanagara Palike**

6. All the rooms are well ventilated and the electrical Lighting Points are adequately fixed for obtainment of good intensive light. All the Electrical control Switches and Sockets are above 6'0" level, to ensure safety. Individual rooms have the Miniature Circuit Breakers to take care of Short Circuits. The Electrical Ducts are laid as per norms of BESCO which are observed to not to affect the safety of the Building.
7. The Drainage pipes are laid as per the norms of BWSSB from the Rest Rooms and are observed that it will not be a hindrance to the safety norms of the building.
8. The Water supply pipes and Over Head Water Storage tank also is observed to be positioned as per the Norms of the Building Safety and all the water ducts are laid as per the norms of BWSSB.
9. All corridors are covered with RCC Mesh wall and MS Hand Rails up to 5'0" height to ensure the safety. The foundation has a framed structure with columns and beams, adequate foundation has been adopted for the structure, and Ground floor as well P.T.Slab roof has been casted. All other structural elements have been executed as per IS Standards with adequate finishing and till date building has been maintained very well. We have not observed any cracks, swelling, sagging in any part of the structure.

We hereby certify that the structure is safe enough to take the loads on the structure. The structure is sound and stable to serve for the rest of its life.

Babawangi

Executive Engineer [Town Planning]
Bruhat Bengaluru Mahanagara Palike
Building Annexe 2, N R Road,
BANGALORE-560 002



ms
12/1/18